

Declaration of Conformity

In accordance with the Construction Products Directive 89/106/EEC, BAGA Water Technology AB, SE-371 48, Karlskrona, hereby declares that the following products meet the requirements of the standard EN12566-3:2005+A1:2009:

"Range of wastewater treatment plant BAGA Easy with BioTank 1hh, 2hh, 3-4hh and 5-6hh".

Approved Bodies: SP Technical Research Institute of Sweden (Report 0402-CPD-SC1725-12) and SINTEF Byggforsk Norway (Technical approval nr. 20117).

	
BAGA Water Technology AB, Torskorsvägen 3, SE-371 48 Karlskrona	
12	
EN12566-3	
Range of wastewater treatment plant BAGA Easy with BioTank: 1 hh / 2 hh / 3-4 hh / 5-6 hh	
Nominal organic daily load (kg BOD₇/d)	0,3 / 0,6 / 0,96 / 1,44
Nominal hydraulic daily flow (m³/d)	0,75 / 1,5 / 2,4 / 3,6
Material	GRP
Water tightness	Passed
Durability	Passed
Vacuum test	Passed
Treatment efficiency at tested hydraulic load 0,85 m³/d and organic load 0,27 kg BOD₇/d:	COD: 94 % BOD₇: 97 % SS: 99 % Ntot: 53 % Ptot: 97 %

Karlskrona 2012-12-04

Bert Gustafsson

